

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

GAF 1361 Alps Road **Wayne, NJ 07470**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: EverGuard® Freedom™ TPO HW and EverGuard® Freedom™ TPO with RapidSeam® Technology Single Ply Roofing System over Poured Gypsum Deck.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 09-0813.02 and consists of pages 1 through 7. The submitted documentation was reviewed by Juan E. Collao, R.A.

Juan E. Wlas

MIAMI-DADE COUNTY

APPROVED

NOA No.: 13-0603.03 **Expiration Date: 09/15/14** Approval Date: 08/01/13

Page 1 of 7

ROOFING SYSTEM APPROVAL

Category: Roofing

Sub-Category: Single Ply Roofing

Materials: TPO

Deck Type: Poured Gypsum

Maximum Design Pressure -490 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT: TABLE 1

Product	<u>Dimensions</u>	Test <u>Specification</u>	Product <u>Description</u>
EverGuard® Freedom TM TPO with RapidSeam® Technology	Various	ASTM D 6878	Self-Adhered thermoplastic olefin reinforced membrane.
EverGuard® Freedom TM TPO HW	Various	ASTM D 6878	Self-Adhered thermoplastic olefin reinforced membrane.
EverGuard [®] TPO 45 mil Utility Flashing Strips	Various	ASTM D 6878	Thermoplastic olefin reinforced flashing membrane.
GAFGLAS® #75 Base Sheet	39.37" (1 meter) wide	ASTM D 4601	Asphalt impregnated and coated glass mat base sheet.
GAFGLAS® #80 Ultima Base Sheet	39.37" (1 meter) wide	ASTM D 4601	Asphalt impregnated and coated, fiberglass base sheet
EverGuard [®] UN 55 T-Joint Cover Patches	100 patches per box	Proprietary	Conforming membrane seal for use over T-joint in 60 and 80 mil membrane applications.
EverGuard® TPO UN-55 Detailing Membrane	Various	ASTM D 6878	Thermoplastic olefin reinforced flashing membrane.
EverGuard® TPO Coated Metal	4' x 8' 4' x 10' sheets	US CS-245-62	EverGuard membrane laminated 24 Ga. galvanized steel.
EverGuard® TPO Preformed Corners	4" x 4" x 4" 20 pcs. Crtn.	ASTM D 6878	Prefabricated molded one piece corners.
EverGuard® TPO Preformed Vent Boots	1" - 8" o.d. 6 pcs. Crtn.	ASTM D 6878	Premolded vent pipe boots.
EverGuard® TPO Cut Edge Sealant	1 quart squeeze tube	Proprietary	Solvent based sealant for TPO cut edges.
EverGuard® Walkway Pads & Rolls	Pads - 1/8" x 30" x 36", Rolls – 1/8"x30"x50'	Proprietary	Standard duty walkway pads & rolls.
EverGuard® Expansion Joint Cover	4"-8" x 50'	Proprietary	Low profile expansion joint cover.
EverGuard® Standard Walkway	1/8" x 30" x 50"	Proprietary	Standard duty walkway pad.
TPO Cover Tape	6" x 100" roll	Proprietary	.045" TPO membrane laminated to white butyl tape



NOA No.: 13-0603.03 Expiration Date: 09/15/14 Approval Date: 08/01/13 Page 2 of 7

<u>Product</u>	Dimensions	Test <u>Specification</u>	Product <u>Description</u>
Preformed Split Pipe Boots	Various	Proprietary	Boots fabricated from .045" thick reinforced TPO membranes
RTS (Roof Transition Anchor) Strip	6" x 110' rolls	Proprietary	TPO membrane with pressure sensitive adhesive
Corner Curb Wraps	Various	Proprietary	Corners are fabricated from 045" thick reinforced TPO membrane
EverGuard Self-Adhering Standing Seam TPO	10' lengths	Proprietary	1-1/2 wide x 1-1/4" high x 10 in length profile with pressure sensitive adhesive and release liner
Freedom [™] 5' x 0" Dual HW (Heat Weld) Flashing	5' x 50'	Proprietary	.045" and 060" reinforced membranes
EverGuard® TPO Fluted Corner	4" x 4" x 4"	Proprietary	Non-reinforced TPO membrane
EverGuard® Inside Corner	6" x 6" x 5½"	Proprietary	Inside corners of base and curb flashings.
EverGuard® Pourable Sealer Pocket	9" x 6" x 4" oval with 3" base flange	Proprietary	Pourable sealer.
EverGuard® Drain	Various	Proprietary	Spun aluminum drain preflshed with 55 mil unreinforced TPO membrane.
EverGuard® Scupper	4" x 6" x 12" 8" x 10" x 12"	Proprietary	TPO coated metal 55 mil unreinforced membrane
EverGuard® Vent	Various	Proprietary	Vent manufactured out of reinforced 45 mil TPO membrane and galvanized steel.
EverGuard [®] Square Tube Wrap	Various	Proprietary	Square tube wrap
TOPCOAT® Flexseal	5 gallons	ASTM D 412 ASTM D 21 ASTM D 1475 ASTM E 1644	Solvent based synthetic elastomeric sealant.
RUBEROID® Modified Base Sheet	39.37" (1 meter) Wide	ASTM D 4601, Type II, UL Type G2 BUR	Premium glass fiber reinforced SBS-modified base sheet
RUBEROID®20	39.37" (1 meter) Wide	ASTM D 6163 ASTM D 5147	SBS modified asphalt base sheet reinforce with a glass fiber mat.
GAFGLAS® STRATAVENT® Eliminator™ Nailable	39.37" (1 meter) Wide	ASTM D 3672 ASTM D 4897	Fiberglass base sheet coated on both sides with asphalt. Surfaced on the bottom side with mineral granules embedded in asphaltic coating.



NOA No.: 13-0603.03 Expiration Date: 09/15/14 Approval Date: 08/01/13 Page 3 of 7

APPROVED INSULATIONS:

TABLE	2
--------------	---

Product Name	Product Description	Manufacturer (With Current NOA)
EnergyGuard TM PolyIso, RA, RN, Ultra	Polyisocyanurate foam insulation	GAF
EnergyGuard™ High Density Fiberboard	High density wood fiberboard insulation.	GAF
EnergyGuard TM Perlite	Perlite insulation board.	GAF
EnergyGuard™ Composite RA, RN	Polyisocyanurate foam insulation with high density fiberboard or perlite insulation.	GAF
Structodek® TD	Flame Resistant High Density Wood Fiber board.	Knight-Celotex
Dens Deck [®] , Dens Deck Prime [®] , Dens Deck DuraGuard TM	Water-resistant gypsum board	Georgia Pacific
Securock TM	Gypsum roof board	USG

APPROVED FASTENERS:

TABLE 3

Fastener <u>Number</u>	Product <u>Name</u>	Product <u>Description</u>	<u>Dimensions</u>	Manufacturer (With Current NOA)
1.	Drill-Tec® CR 1.2 Base Sheet Fastener and Plate	Base sheet fastening assembly.		GAF
2.	Drill-Tec [®] Locking Impact Nail	Base sheet fastener with integrated Plate.	1.8" long w/ 2.7" dia. plate	GAF

EVIDENCE SUBMITTED:

Test Agency/Identifier	<u>Name</u>	Report	<u>Date</u>
Underwriters Laboratory, Inc.	03CA38009	UL 790	01/21/04
IRT-ARCON, Inc.	02-011 02-015 04-005 04-022	TAS 114 TAS 114 TAS 114 TAS 114	02/26/02 03/26/02 03/19/04 05/14/04
Factory Mutual Research Corp.	FMRC 4470 FMRC 4450	3020588 3015029	03/24/04 02/19/04
Atlantic & Caribbean Roof Consulting, LLC	08-033	TAS 114	05/19/08

NOA No.: 13-0603.03 Expiration Date: 09/15/14 Approval Date: 08/01/13 Page 4 of 7



APPROVED ASSEMBLIES:

Membrane Type: TPO

Deck Type 6: Poured Gypsum, Insulated

Deck Description: Poured Gypsum

System Type A: Anchor sheet mechanically fastened; all layers of insulation adhered.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Insulation Layer Insulation Fasteners Fastener (Table 3) Fastener

 $Energy Guard^{TM}\ Poly Iso,\ RA,\ RN$

Minimum 1.3" thick N/A N/A

Note: All insulation shall be adhered to the anchor sheet in ¾" to 1" wide beads 6" o.c. of OlyBondTM 500 Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Anchor sheet: One ply of GAFGLAS® #75 Base Sheet, GAFGLAS® #80 UltimaTM Base Sheet,

GAFGLAS® STRATAVENT® Eliminator™ Nailable, RUBEROID® Modified Base Sheet or RUBEROID® 20 mechanically fastened as described below:

Fastening Options: Drill-Tec™ CR 1.2" Base Sheet fasteners at a 2" side lap 9" o.c. and in two rows

staggered in the center of the sheet 12" o.c.;

(Maximum Design Pressure -50 psf, See General Limitation #9)

Drill-Tec[™] CR 1.2" Base Sheet fasteners at a 4" side lap 7" o.c. and in three rows

staggered in the center of the sheet 7" o.c.;

(Maximum Design Pressure -52.5 psf, See General Limitation #7)

Drill-Tec[™] 1.8" Locking Impact Nail fasteners at a 4" side lap 9" o.c. and in two

rows staggered in the center of the sheet 12" o.c.;

(Maximum Design Pressure -75 psf, See General Limitation #7)

Membrane: EverGuard[®] Freedom[™] TPO with RapidSeam[®] Technology 45, 60, 80 mil

adhered to insulation with a minimum 6" side lap fully self-adhered

or

EverGuard® FreedomTM TPO HW 45, 60, 80 mil (self-adhered) with a minimum

3" side lap heat welded with a minimum 1.75" weld.

Surfacing: (Optional) Applied according to manufacture specifications.

1. Advanced Green Technologies Photovoltaic Laminate solar energy collector auxiliary roof equipment installed in compliance with manufacturer's specifications and applicable Building Codes.

2. EverGuard® Self-Adhering Standing Seam TPO installed in compliance with

manufacturer's specifications and applicable Building Codes.

3. TOPCOAT® Surface Seal, TOPCOAT® Fireshield® SB Solvent based

Elastomeric Roofing Membrane applied at 1to 1.5 gal./sq.

Maximum Design

Pressure: See Fastening Options Above

MIAMI-DADE COUNTY
APPROVED

NOA No.: 13-0603.03 Expiration Date: 09/15/14 Approval Date: 08/01/13 Page 5 of 7 **Membrane Type:** TPO

Deck Type 6: Poured Gypsum

Deck Description: Poured Gypsum Concrete

System Type F: Membrane fully adhered directly to primed roof deck

All General and System Limitations shall apply.

Primer: Gypsum deck shall be primed with GAF TOPCOAT® Surface Seal SB applied at a

rate of .83 gallons per square.

Membrane: EverGuard[®] Freedom[™] TPO with RapidSeam[™] Technology 45, 60, 80 mil self

adhered to the Gypsum concrete deck with a minimum 6" side lap fully self-

adhered or

FreedomTM TPO HW 45, 60, 80 mil (self-adhered) with a minimum 3" side lap

heat welded with a minimum 1.75" weld..

Surfacing: (Optional) Applied according to manufacture specifications.

1. Advanced Green Technologies Photovoltaic Laminate solar energy collector auxiliary roof equipment installed in compliance with manufacturer's specifications and applicable Building Codes.

2. EverGuard® Self-Adhering Standing Seam TPO installed in compliance with

manufacturer's specifications and applicable Building Codes.

3. TOPCOAT® Surface Seal, TOPCOAT® Fireshield® SB Solvent based

Elastomeric Roofing Membrane applied at 1to 1.5 gal./sq.

Maximum Design

Pressure: -490 psf (See General Limitation # 9)



NOA No.: 13-0603.03 Expiration Date: 09/15/14 Approval Date: 08/01/13

Page 6 of 7

GENERAL LIMITATIONS:

- 1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
- 3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
- 4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

- 5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
- 6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
- 7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant (When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
- 8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
- 9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). (When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)
- 10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

MIAMI-DADE COUNTY

NOA No.: 13-0603.03 **Expiration Date: 09/15/14** Approval Date: 08/01/13

Page 7 of 7